

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3225-0935:113 Page 1 of 1

CATEGORY: Fire Dampers

LISTEE: Nailor Industries, 4714 Winfield Rd, Houston TX 77039
Contact: John Young (281) 590-1172 FAX (281) 590-3086

PRODUCT: Models D0100 and D0500 fire dampers. These dampers are of the curtain blade type construction for vertical and horizontal installation for use in dynamic (fans on) systems, where the HVAC system remains operative in the event of a fire. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: Model D0100 is rated for 1½ hours
Model D0500 is rated for 3 hours

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, fire rating, and UL label.

APPROVAL: Listed as fire dampers rated for 1½-hour or 3 hours for use in HVAC duct systems passing through fire resistive walls or partitions. Refer to listee's Installation Instruction Manual for details.

NOTE: Leakage rating not evaluated. Refer to CSFM Listing Category 3230 for listed leakage dampers.

05-10-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JULY 13, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**